

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215284
Address: 3639 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643639 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643639 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643639 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Monday, August 15, 2022

Informational:

1 Misc

-Attic separation-2nd layer ok

-Dwelling separation-2nd layer ok

**close roof deck and exterior wall holes within 4 ft of firewall with fire-resistant plywood

Comments: