

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211620
Address: 2329 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, August 15, 2022

Corrective Action Required:

1 Misc

- submit TCO extension form
- address failed pier inspection
- address siding from grade at back of lot
- (2) 1/2" through bolts at each deck post to beam connection
- sump pump discharge to extend 36" from foundation

Comments: