



August 12th, 2022

K&E Flatwork, Inc

Re: 4809 NE Freehold Court
Lot 128, Monticello
Lee's Summit Permit #:PRRES20222650

Apex Engineers, Inc. observed the preparation for the basement slab at the above referenced address.

The basement slab will bear on existing grade. A vapor barrier was present in the living area with the proper base course.

Note:

- The inspection was performed at 9:00am
- At the time of the inspection the temperature was 78°.
- Erosion control was in place at the time of the inspection.

Our firm recommends approval of the basement slab for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,

Christopher Veith
Senior Engineering Technician

Clayton J. Hess P.E.
Principal

