

DEVELOPMENT SERVICES

Building Permit - Commercial	Permit No: PRCOM20220586
Project Title: PNC BANK	Date Issued: August 16, 2022
Work Desc: NEW COMMERCIAL	

Project Address: 908 NW PRYOR RD
908 NW PRYOR RD, LEES SUMMIT, MO 64081

RYCON CONSTRUCTION INC
2501 SMALLMAN ST SUITE 100
PITTSBURGH, PA 15222

Parcel No: 258005

County: JACKSON

Activities Included for this Project:

zNew Commercial, License Tax, License Tax Credit,

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS.

NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

Fire Plan Review

- 2018 IFC 1008.3.1 & 3.2 Emergency power for illumination. The power supply for means of egress illumination shall normally be provided by the premises' electrical supply. In the event of power supply failure, an emergency electrical system shall automatically illuminate all of the following:
- 1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.
- 2. Corridors, interior exit stairways and ramps and exit passageways in buildings required to have two or more exits.
- 3. Exterior egress components at other than their levels of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.

Action required- Provide a lighting fixture with an emergency battery back-up over the front door discharge.

Building Plan Review

Licensed Contractors

Signature of

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

Applicant:	Date:
Print name:	Company Name: