

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220752

Address: 1980 SE BLUE PKWY, Unit:2302, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, August 16, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Provide address-Service counter in lobby to be max 34" aff-Provide accessible restroom signage-Mirror in restroom to be max 40" to reflective surface-Grab bar behind toilet to be max 6" from side wall and min 42" from side wall-Restroom walls to have non absorbant finish at all walls within 2' of sink or toilet to min 48" aff-Provide panel labels and panel schedules in electrical room-Complete all corrections for Fire Department
---	------	--

Comments: