

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20215290
Address: 2200 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Eric Sharp	Passed	Wednesday, August 17, 2022

Informational:

1 Misc

Crews worked on backfilling between existing surface and curb, using KCM MB concrete to fill up to 2-3" below level. 7/7/22 ES

Marked out asphalt down Lowenstein and emailed Codi with what we want to see done with the wedging down this stretch. 7/15/22 ES

Seal-O-Matic milled out 4' from curb line and laid type 6 asphalt down north side of Lowenstein Dr. 7/30/22 ES

Comments: