

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215139

Address: 3723 SW MARYVILLE PL, LEES SUMMIT, MO 640823725 SW MARYVILLE PL, LEES SUMMIT, MO
640823727 SW MARYVILLE PL, LEES SUMMIT, MO 640823721 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Wednesday, August 17, 2022

Corrective Action Required:

1	Misc	3727-Roof vent in attic within 4' of fire wall. -Fur out laundry room for dryer vent , firestop at the top plate. -Nail electrical box right of slider. -Support gas line. -No elect to entry light . 3725 -Support HVAC pvc vent . -Move flex duct over attic access. -Fire stop fur out for laundry vent . 3723 -roof vents. - support HVAC 3721 - support HVAC - roof vents.
---	------	---

Comments:

