

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20215859  
**Address:** 1605 SW 27TH ST, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Mitchell Schwarz	Failed - Stop Work	Wednesday, August 17, 2022

**Corrective Action Required**

1	Misc	-frost footing need be per plans 36" deep from grade -garage pads per plans
---	------	--

**Corrective Action Required**

2	Misc	footing poured without approval.
---	------	----------------------------------

**Comments:**