

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line Construction Inspection	Eric Sharp	Partial	Wednesday, August 17, 2022

Informational:

1 Misc

RMC was onsite with Rob from Haren today to flush the fire line to prepare for sprinkler installation. Flushed line from 1:45-2:10 with no issues then closed fire line valve and replaced cap on line coming into building. 8/17/22 ES

Comments: