

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220046
Address: 2026 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, August 18, 2022

Corrective Action Required:

1 Misc

- plans call for 2 2x10 above double car garage
- address holes above bar area in floor joist drilled too close together fix to engineer specifications
- fire block furr out wall to ceiling space in basement W wall and
- fire block stairwell to basement

Okay to insulate do not cover any items in need of inspection

Comments: