

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215552  
Address: 110 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Thursday, August 18, 2022

Corrective Action Required:

1	Misc	- Steps at garage more yhan 3/8" variance
		- saftey caps on A/C compressor required
		- Provide gutters and down spouts
		- splash blocks

**Comments:**