

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213629
Address: 1519 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, August 18, 2022

Corrective Action Required:

1	Misc	-address piers poured without inspection -provide as graded plot plan -sod -check water meter at time of sod -splash blocks and sump pump discharge to extend 36" from foundation -label all non GFCI outlets in unfinished spaces
---	------	---

Comments: