

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212067
Address: 1406 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, August 18, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fees -final driveway and sidewalk inspections required contact development services to schedule -final grade and sod -splash blocks -provide code compliant deck ledger lags, truss structural screws not approved for deck ledger attachment -install attic access cover garage -label all breaker locations -provide ladder basement egress well
---	------	---

Comments: