

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Thursday, August 18, 2022

Corrective Action Required:

1	THIRD FLOOR	AREA "A"
---	-------------	----------

use approved fire caulk at tension rods throughout

337-H2.5 on both plies of GT

334 -seal gaps in vertical Fireblocking, install roof hydrant ,support dwv in attic space

332-add stud at laundry wall,

335-seal fireblocking at

330-correc joist hanger at entry

328- add stud in corridor, vertical

333-support dwv in attic.

Fireblocking at stairwell wall,

331-support dwv 4' oc

326-missing dampers at hvac

324-ok

309-correct roofing fire separation

Comments:

