

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20220570  
Address: 1120 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Robb Popp	Partial	Thursday, August 18, 2022

Informational:  
1 Misc

EXTERIOR GRADE BEAM AND PAD:  
LINE T: 1-10;  
LINE 10: T-P  
LINE 1: T-L

INTERIOR COLUMN PADS-OK TO POUR:  
-LINE 2: D TO T  
-LINE 3: E TO T  
-LINE 4: E TO T  
-LINE 5: F TO T  
-LINE 6: F TO T  
-LINE 7: G TO T  
-LINE 8: G TO T  
-LINE 9: G TO T

UFER LOCATED AT NE CORNER AT 1/R LINES

**Comments:**