

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213480
Address: 125 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, August 19, 2022

Corrective Action Required:

1	Misc	- raise water meter height to grade. meter is lower than the required 18" from lid to lid. adjust and reschedule not completed at time of inspection. Mitchell Schwarz 08/19/2022 8:14 AM
---	------	---

Comments: