



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110060, Building Permit - Commercial
Address: 970 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|-----------|---------------------------|
| Gas Service Inspection - Commercial | John Borns | Not Ready | Wednesday, March 30, 2011 |

Corrective Action Required
1 MISC

GAS PIPING PRESSURE BELOW 10 PSI REQUIRED MINIMUM.
PRESSURIZE PIPING SYSTEM TO HOLD STEADY AT MINIMUM 10
PSI.

| | | | |
|---|------------|-----------|---------------------------|
| Gas Piping Inspection - Commercial | John Borns | Not Ready | Wednesday, March 30, 2011 |
|---|------------|-----------|---------------------------|

Comments: