

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221737
Address: 4732 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, August 19, 2022

Corrective Action Required:

1	Misc	-Install windows and doors and nail siding per code
		-Provide attic access to roof space above garage **Need min 30" headroom clearance
		-Provide min 2 anchors for garage column
		-Over notched joist above garage near I beam
		-Fb duct chase from joist space
		-Fb floor at plumbing trap; Fb plumbing space in office from soffit&joist space
		-Seal gaps along studs of return air space at front 2nd fl bathroom
		**OK TO INSULATE

Comments: