

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20216366

Address: 3635 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:WTR, LEES SUMMIT,
MO 640643695 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643635 NE AKIN DR,
Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Adam Nacke	Partial	Friday, August 19, 2022

Informational:

1 Misc

6-1-22 AN there are are 3 mains south, middle and north. South line will be 1 test and middle will be 1 test and north will be 3 test

8-15-22 AN spoke with Brent from water and he informed me that water samples are not required because a back flows are in place

8-18-22 AN water department has come back and told us that they now want water samples from the 3 lines

Comments: