

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213777
Address: 3212 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, August 19, 2022

Corrective Action Required:

1	Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -address pending footing inspection -address pending driveway and sidewalk inspections -address to be properly illuminated -outlets in master bath not working -spindles at stairs guard rail -set screw sheered off at water anti syphon device
---	------	---

Corrective Action Required:

2	Misc	inspection denied, address letter needed for footing inspection as indicated in footing inspection. Mitchell Schwarz 08/19/2022 9:36 AM
---	------	--

Comments: