

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213784  
Address: 2617 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, August 19, 2022

Corrective Action Required:

1	Misc	submit tco extension request fourm. Mitchell Schwarz 08/19/2022 10:35 AM  TCO UNTIL 7/29/22 -address drive way and sidewalk inspection pending -final grade and sod -gutters to be installed -splash blocks and sump pump discharge to extend 36" from foundation -obtain lawn irrigation permit -check water meter at time of final grade and sod
---	------	---

Comments: