

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20220491

Address: 1161 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Friday, August 19, 2022

Corrective Action Required:

1	Misc	-Color/tag/ ID MC support wires -Secure MC within 12" of j-boxes, except where the MC directly go to the ceiling lights -Circuits to ceiling lights above patient care area must meet NEC 517.13 -Support ceiling grid at max 4 ft interval. Twist wire min 3 times
---	------	--

Comments: