

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222308
Address: 1469 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Friday, August 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Pay all fees -Provide anti siphon devices at hose bib -Provide grab bars at restrooms -Lower mirrors in restrooms to 40" aff to reflective surface
---	--------------------------	--

Comments: