

NLV Lot 7

Backflow Prevention Assembly Test Report

Service Address

Location Mech cm.

Mailing Address

Mailing Phone

420 SW Longview Blvd
STE. 116

Serial #: 101785 ☒ Check if Correct ☐ Corrections

Manufacturer: Watts ☒

Model: LF009M2QT ☒

Type: RPZ ☒

Size: 1/2 ☒

Orientation: Horizontal ☒

Protection: Domestic ☒

Hazard: Domestic

Meter#:

Premise ID:

SPID:

Test Due No
Later than:

Existing ☒ New ☒

Removed ☐ Replaced ☐

Commercial ☐ Industrial ☐

Residential ☐

Construction ☒

Domestic ☒ Irrigation ☐ Fire ☐

Reduced Pressure Principle Assembly Double Check Valve Assembly

Air Gap Required Separation Yes ☒ No ☐

PVB/SVB

Check Valve #1

Check Valve #2

Relief Valve

Air Inlet

Check Valve

Initial Test

Date 6-1
Time 7:15

Leaked ☐
Closed Tight ☒
Held at 7.8 PSID

Leaked ☐
Closed Tight ☒
Held at 1.4 PSID

Did not open ☐
Opened at 2.8 PSID

Did not open ☐
Opened at ____ PSID

Leak ☐
Held at ____ PSID

Repairs

Date _____
Time _____

Cleaned ☐
Replaced ☐
Rubber Kit ☐
CV Assembly ☐
Disc ☐
O-rings ☐
Seat ☐
Spring ☐
Stemguide ☐
Retainer ☐
Lock Nuts ☐
Other ☐

Cleaned ☐
Replaced ☐
Rubber Kit ☐
CV Assembly ☐
Disc ☐
O-rings ☐
Seat ☐
Spring ☐
Stemguide ☐
Retainer ☐
Lock Nuts ☐
Other ☐

Cleaned ☐
Replaced ☐
Rubber Kit ☐
RV Assembly ☐
Disc ☐
Diaphragm(s) ☐
Seat ☐
Spring ☐
Guide ☐
O-rings ☐
Other ☐

Cleaned ☐
Replaced ☐
Rubber Kit ☐
Disc ☐
Spring ☐
Retainer ☐
Guide ☐
O-rings ☐
Other ☐

Cleaned ☐
Replaced ☐
Rubber Kit ☐
CV Assembly ☐
Disc ☐
Spring ☐
Retainer ☐
Guide ☐
O-rings ☐
Other ☐

Final Test

Date _____
Time _____

Closed Tight
Held at ____ PSID

Closed Tight
Held at ____ PSID

Opened at ____ PSID

Opened at ____ PSID

Held at ____ PSID

Notify us if failed assemblies cannot be repaired within three days.

Comments:

Proper Installation ☒ Yes ☐ No
RV Exercised ☒ Yes ☐ No
#2 Shutoff Closed ☒ Yes ☐ No
Service Restored ☒ Yes ☐ No

I certify all information on this report is true and accurate, acknowledging that incomplete reports will not be accepted.

Tester Matt Murdick

Certification # 51102 1-31-2025 Phone 913-318-9493

Test Kit Serial # TK-9A 864736 Calibration Date 9-13-21

Signature:

Line Pressure 68 psi

Meter Reading N/A

Passed ☒ Failed ☐


KC

Return completed
Test Report to:

Kansas City Water Services
2409 E. 18th St.
Kansas City, MO 64127
Phone: 816-513-4795 Fax: 816-513-4798
Email: backflow@kcmo.org

NLV Lot 7

Backflow Prevention Assembly Test Report

Service Address

Location Mech rm.

Check if Correct Corrections

Serial #: 249787 ☒

Manufacturer: Watts ☒

Model: LF009M2QT ☒

Type: RPZ ☒

Size: 1" ☒

Orientation: Horizontal ☒

Protection: irrigation ☒

Mailing Address

Mailing Phone

420 SW Longview Blvd
STE. 116

Hazard: irrigation

Meter#:

Premise ID:

SPID:

Test Due No
Later than:

Existing ☐
New ☒

Removed ☐
Replaced ☐

Commercial ☐
Industrial ☐

Residential ☐

Construction ☒

Domestic ☐

Irrigation ☒ Fire ☐

Reduced Pressure Principle Assembly Double Check Valve Assembly

Air Gap Required Separation Yes ☒ No ☐

PVB/SVB

Check Valve #1

Check Valve #2

Relief Valve

Air Inlet

Check Valve

Initial Test

Date 02/05/16
Time 7:45

Leaked ☐
Closed Tight ☒
Held at 6.8 PSID

Leaked ☐
Closed Tight ☒
Held at 1.6 PSID

Did not open ☐
Opened at 2.8 PSID

Did not open ☐
Opened at ____ PSID

Leak ☐
Held at ____ PSID

Repairs

Date _____
Time _____

Cleaned ☐
Replaced ☐
Rubber Kit ☐
CV Assembly ☐
Disc ☐
O-rings ☐
Seat ☐
Spring ☐
Stemguide ☐
Retainer ☐
Lock Nuts ☐
Other ☐

Cleaned ☐
Replaced ☐
Rubber Kit ☐
CV Assembly ☐
Disc ☐
O-rings ☐
Seat ☐
Spring ☐
Stemguide ☐
Retainer ☐
Lock Nuts ☐
Other ☐

Cleaned ☐
Replaced ☐
Rubber Kit ☐
RV Assembly ☐
Disc ☐
Diaphragm(s) ☐
Seat ☐
Spring ☐
Guide ☐
O-rings ☐
Other ☐

Cleaned ☐
Replaced ☐
Rubber Kit ☐
Disc ☐
Spring ☐
Retainer ☐
Guide ☐
O-rings ☐
Other ☐

Cleaned ☐
Replaced ☐
Rubber Kit ☐
CV Assembly ☐
Disc ☐
Spring ☐
Retainer ☐
Guide ☐
O-rings ☐
Other ☐

Final Test

Date _____
Time _____

Closed Tight
Held at ____ PSID

Closed Tight
Held at ____ PSID

Opened at ____ PSID

Opened at ____ PSID

Held at ____ PSID

Notify us if failed assemblies cannot be repaired within three days.

Comments:

Proper Installation

Yes ☒ No ☐

RV Exercised

Yes ☒ No ☐

#2 Shutoff Closed

Yes ☒ No ☐

Service Restored

Yes ☒ No ☐

I certify all information on this report is true and accurate, acknowledging that incomplete reports will not be accepted.

Tester Matt Mordick

Certification # 51102 1-31-2025

Phone 913-318-9493

Test Kit Serial # TK-9A 864736

Calibration Date 9-31-21

Signature

Line Pressure 68psi

Meter Reading N/A

Passed ☒ Failed ☐


KC

Return completed
Test Report to:

Kansas City Water Services
2409 E. 18th St.
Kansas City, MO 64127
Phone: 816-513-4795 Fax: 816-513-4798
Email: backflow@kcmo.org