

## ANALYTICAL REPORT

March 30, 2011

Work Order: 11C1336

Page 1 of 3

### Report To

Bill Lyon  
City of Lee's Summit - Public Works Dept.  
220 SE Green Street  
Lees Summit, MO 64063

### Work Order Information

Date Received: 03/29/2011 10:19AM  
Collector: Lyon, Bill  
Phone: (816) 969-7428  
PO Number: Routine Analysis

Project : Blue Moon Hauling LLC

Project Number: LSHS Watermain Ext.

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
11C1336-01	Sta. 1+50			Matrix:Drink Wtr		Collected: 03/29/11 09:32	
Total Coliforms	<1.0 MPN/100 ml	1.0	1C12914	9223B-QT	CLJ	03/29/11 10:50	
E. Coli	<1.0 MPN/100 ml	1.0	1C12914	9223B-QT	CLJ	03/29/11 10:50	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL = Method Reporting Limit.

City of Lee's Summit - Public Works Dept.  
220 SE Green Street  
Lees Summit, MO 64063

March 30, 2011  
Page 2 of 3

Work Order: 11C1336


## Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC
	E. Coli	KS-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2011
KS-NT	Kansas Department of Health and Environment	E-10287	10/30/2011
NELAC	New Jersey Department of Environmental Protection	IA001	06/30/2011
SIA1X	Iowa Department of Natural Resources	95	02/01/2012

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson  
Project Manager