

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222308
Address: 1469 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, August 22, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Pay License Tax Fee -Provide grab bars at restrooms- vertical grab bar in women's room to be 39-41" from back wall and 39-41" aff
---	--------------------------	---

Comments: