

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221422

Address: 3503 SW MARKET ST, LEES SUMMIT, MO 640823505 SW MARKET ST, LEES SUMMIT, MO 640823507
SW MARKET ST, LEES SUMMIT, MO 640823509 SW MARKET ST, LEES SUMMIT, MO
640823501 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|--------------|----------|-------------------------|
| Fire Line - Hydrostatic Test | Ryan Heckman | Passed | Monday, August 22, 2022 |

Informational:

1 Misc

8-19-22 RH. Contractor flushed the fire line. Planned hydrostatic test at 10am.

8-22 RH. Hydrostatic test started 7:49am. Pressure was put at 200psi and held at the start.

8-22 RH. Hydrostatic test passed holding the 200 psi pressure for 2 hours.

Comments: