

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215487  
Address: 2002 SW 26TH TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection</b>	Diana Johnson	Partial	Monday, August 22, 2022

Informational:

1 Misc

On 4.12.2022 Tuesday Temp Stop installed 100 ft of 2-inch flexible plastic water service line. Proper bedding was utilized.

8-22-22 RH. Backflow and water meter was installed and filled around.

**Comments:**