

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220521
Address: 3216 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, August 22, 2022

Corrective Action Required:

2	Misc	-seal top plate penetrations at pfh -seal furr out walls into furr down in garage (seal gaps) -missing stud packs at GT bearing points in garage W wall -fireblock dead space to ceiling space at garage entry -protect NM with 6' of attic access -ufer ground rod connection to remain accessible -fire block basement stairwell walls vertically horizontally every 10' seal gaps -missing truss hanger at front patio
---	------	--

Comments: