

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215563  
Address: 1620 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome: | Date:                   |
|---|------------------|----------|-------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Failed   | Monday, August 22, 2022 |

Corrective Action Required:

1 Misc

-will check GB bracing at time of completion schedule for reinspection at this time

-solid block sheathing breaks through out 2nd floor see bed 3

Okay to insulate do not cover any items in need of inspection

**Comments:**