

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215236  
Address: 1521 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, August 23, 2022

Corrective Action Required:

1	Misc	-fire block garage S wall into furr down see hvac chase -tie bath 4 exterior wall top plate to garage exterior wall top plate -nail truss fixes above bed 5 per manufacture specifications -seal all penetrations through air returns -Support HVAC flex duct 2nd floor attic -incorrect hanger on D7, LUS26 per plans -fireblock vertical to horizontal every 10' at basement stairwell
---	------	--

Comments: