

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214073
Address: 432 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, August 23, 2022

Corrective Action Required:

1	Misc	Provide gutters and down spouts Remove dirt from water meter pit and add gravel in bottom Single outlet in laundry mark non gfci Uncover smoke detectors Complete gas service Garage door must be self closing and latch
---	------	---

Comments: