

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200
Fax (816) 969-1201

PLAN REVIEW CONDITIONS

March 31, 2011

KCG Architects
21 Grand Ave Suite #201
Palisades, NJ 07650

Permit No: PRCOM20110115
Project Title: The Children's Place
Project Address: 970 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086
Parcel Number: 51700033300000000
Location: SUMMIT FAIR LOTS 22A & 24A---LOT 22A
Type of Work: New Tenant Finish
Occupancy Group: Mercantile
Description: Retail clothing sales

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved

3. Submittal Requirements:

General contractor/permit holder and MEP subs must be listed on permit prior to issuance.

Fire Plan Review

Reviewed By: Jim Eden

Approved

3. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

5. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required: Fire protection systems shall be tested and operable prior to scheduling an occupancy testing. Testing shall take place before or after regular business hours for the neighboring tenants. cal (816) 969-1300 to schedule a test.

- ☒ Approved to issue per the listed conditions.
☐ Do not issue per the listed conditions.
☐ Approved to construct foundation only per the listed conditions.
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.