CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215066

Address: 2102 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822104 SW HOLDBROOKS DR, LEES SUMMIT,

MO 640822106 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822108 SW HOLDBROOKS

DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Electrical Service Inspection Patrick Schonfeldt Failed Tuesday, August 23,

2022

Corrective Action Required:

1 Misc UNIT 2102: -remove panel bonding screw from sub panel

UNIT 2104: INTERIOR OK

UNITS 2106, 2108 AND EXTERIOR SERVICE NOT INSPECTED

Comments: