



FIRE DEPARTMENT

**Prevention Division
(816)969-1300**

PLANS REVIEW CONDITIONS

Permit No: PRCOM20213548 Date: August 23, 2022
Project Title: SIGNATURE AT WEST PRYOR PHASE 2 - Applicant:
BUILDING 1
Location: LYNN ELECTRIC & COMMUNICATIONS INC
2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081 725 N 2ND ST STE K
Type of Work: LAWRENCE, KS 66044
Occupancy Group: R-2
Description: NEW APARTMENT BUILDING Primary: (785) 843-5709
Construction Type: Type VA (1 hour)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Revised plans received July 18, 2022.

2. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

The alarm system will be tested at the sprinkler flow test. Call (816) 969-1300 if you have any questions about testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.