



CITY OF LEE'S SUMMIT
PUBLIC WORKS DEPARTMENT / INSPECTIONS DIVISION
220 SE Green Street
LEE'S SUMMIT, MISSOURI 64063

(816) 969-1800 FAX (816) 969-1810

Certificate of Substantial Completion

March 31, 2011

*JE Dunn Construction Company
1001 Locust Street
Kansas City, Mo 64106
Attention: Bryan Roth*

RE: Lee's Summit High School's Multi - Purpose Building

A Certificate of Substantial Completion is hereby released by the City of Lee's Summit Public Works Department / Inspections Division for the above referenced commercial project. All infrastructures for the site have been constructed per the approved plans. Incomplete items are indicated in the punch list below. Punch list items must be satisfied prior to receiving a Certificate of Final Acceptance from Public Works.

1. Sod needs to be placed on the south side slope to the new building.
2. The three private 8" Nyloplast storm sewer drains need to be lowered per our March 30, 2011 conversation.
3. East slope on the property behind new building needs to be graded and seeded with mulch.


The Contractor / Developer have 90 days from issuance of this certificate to complete the identified punch list items.

If you have any questions regarding the above items please contact Bill Lyon, Public Works Inspector (816) 969 - 1829 or Tony Reams, Staff Engineer at (816) 969 - 1826.

Sincerely,


Developer (Signature & Date)

3-31-2011


Public Works Inspector (Signature & Date)

Copy: PW Records Tech
PW Inspections Supervisor
GIS Manager
File

Financial Analyst
Development Engineering
Public Works Operations
Contractor

Codes Admin.
Codes Admin Manager
Water Operations
Engineer



"An American Public Works Association Accredited Public Works Department"