



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110060, Building Permit - Commercial  
Address: 970 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, March 31, 2011

Partial Correction  
1 MISC

5/8" TYPE X GWB AT SOUTH FACE OF CORRIDOR WALL @ LOBBY NORTH OK TO TAPE, MUD, AND FIRE-SEAL.

<b>Gas Service Inspection - Commercial</b>	John Borns	Failed	Thursday, March 31, 2011
--	------------	--------	--------------------------

Corrective Action Required  
1 MISC

GAS PIPING PRESSURE TEST LOST PRESSURE DURING MONITORING PERIOD. PRESSURIZE PIPING SYSTEM TO HOLD STEADY AT MINIMUM 10 PSI.

<b>Gas Piping Inspection - Commercial</b>	John Borns	Failed	Thursday, March 31, 2011
---	------------	--------	--------------------------

Corrective Action Required  
1 MISC

SUPPORT OF RIGID STEEL ROOFTOP GAS PIPING: IFGC 407; 415: 8' MAXIMUM SPACING FOR 1" PIPE

**Comments:**