

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220757
Address: 1601 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, August 24, 2022

Corrective Action Required:

1 Misc

- strap top plate in office closet
- uncover cover patio for inspection
- address valley rafter landing at dining/living room/kitchen
- address over notched ceiling joist at dining/living room/kitchen
- address over notched double 2x12 at great room windows
- seal penetrations in return air joist space bath/bed 4 entry
- security blocking at basement back door
- provide and up load plans for engineered I joist for inspection

Comments: