

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215028
Address: 2601 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|--------------|----------|----------------------------|
| Electrical Service Inspection | Khanh Nguyen | Failed | Wednesday, August 24, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Submit revised plan to match service -Please recheck all conductors sizing. Ex; 4/0 Alum GEC for (3)400 kcmil SE conductors, etc |
|---|------|--|

Comments: