

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220521  
Address: 3216 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome: | Date:                     |
|-------------------------------------------|------------------|----------|---------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Failed   | Thursday, August 25, 2022 |

Corrective Action Required:  
2 Misc

- missing stud pack garage w wall see bath 4 (3) 2x4
- fireblock dead space to ceiling space at garage entry seal gaps
- ufer ground rod connection to remain accessible

Okay to insulate do not cover any items in need of inspection

**Comments:**