

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215028
Address: 2601 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|------------|----------|---------------------------|
| Pavement-Proof Roll | Adam Nacke | Partial | Thursday, August 25, 2022 |

Informational:

| | | |
|---|------|---|
| 1 | Misc | 8-24-22 AN. Crew did a proof roll and there was one bad spot. |
| | | 8-25-22 AN. Crew dug up the bad spot 15' x 10' x 4' deep and is filling it with type5 |

Comments: