

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Thursday, August 25, 2022

Corrective Action Required:

1 FIRST FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS EXCEPT AS NOTED:
133-incomplete

AREA C
UNITS AND CORRIDORS APPROVED EXCEPT AS NOTED
-Correct penetrations in shaft wall
-147-fireblock corner of laundry ceiling line
-159 not ready

AREA B
148-support dwv
145-support sec, corridor, nail stud shoes
146-OK
143-support sec, protect nm at living room,
141-seal penetration at sec, secure AC AND NM IN STUD SPACE
Amenities- midpoint strap dwv, seal gaps at mailboxes,
-Address penetrations at shaft wall, plate penetrations at locker room and support dwv
144-Bocca plate at corridor

Corrective Action Required:

2 SECOND FLOOR THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS
AREA "B" UNITS AND CORRIDORS
AREA "C" UNITS AND CORRIDORS

Corrective Action Required:

3 THIRD FLOOR THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS
AREA "B" UNITS AND CORRIDORS
AREA "C" UNITS AND CORRIDORS

Corrective Action Required:

4 STAIR TOWER 1 STAIR TOWER "A"
-3RD FLOOR OK

Corrective Action Required:

5 STAIR TOWER 2 STAIR TOWER "B"
-3RD FLOOR OK

Corrective Action Required:

6 STAIR TOWER 3 STAIR TOWER "C"
-3RD FLOOR OK

Comments: