

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20220363
Address: 3990 SW FLINTROCK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit	Diana Johnson	Partial	Monday, July 18, 2022

Informational:	
1 Misc	On Thursday 3.17.2022 No Activity today
Informational:	
2 Misc	No activity or work being performed. 3/24/22 ES
Informational:	
3 Misc	No work being performed. 3/30/22 ES
Informational:	
4 Misc	Jarrods crew was on-site working on storm final storm line. Spoke with him about complaint of erosion/mud issues. He had already scraped the roadway and said he would keep an eye on it. 4/20/22 ES
Informational:	
5 Misc	7-18-22 RH. Visited site and no development work was going.
Informational:	
6 Misc	7.29.2022 Site needs vegetation, one sewer lateral is down, storm sewer box lids need to be grouted, cut all expansion joint material in curb gutter, and remove asphalt manhole cover.

Comments: