

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220180
Address: 525 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, August 25, 2022

Corrective Action Required:

1	Misc	PFH portal frame, nail 2x4 to header per plan 2 rows @ 3" on center #16 sinkers
		8/28/22 - UPLOAD MANUFACTURER DOCUMENTATION ON TRUSS HOLD DOWNS USED AT COVERED DECK, CONFIRM SCREWS USED ARE DESIGNED AS TRUSS HOLD DOWNS

Comments: