CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20214475 Address: 205 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Thursday, August 25, 2022
Corrective Action Required:			

conectiv	e Action Required.	
1	Misc	-Final grade, sod, splash blockss, sump extension
		-Shut off for exterior gas appliance to be within 6'
		-Fireblock dead space at exterior fireplace
		-Stair risers to basement to be no greater than 7 3/4" and vary no more than
		3/8"
		-Provide 1" clearance to combustibles at furnace B vent

Comments: