

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213431
Address: 420 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Storm Sewer Construction Inspection	Eric Sharp	Passed	Thursday, August 25, 2022

Informational:		
1	Misc	Temp Stop installed boxes 105 and 106 after connecting to existing 15" storm pipe. They also poured collars and were pouring inverts this afternoon.
Informational:		
2	Misc	Temp Stop installed 6 roof drains and connected them to the storm box. Informed them to get the correct storm lid (missing the stamping info). RP 11-11-21
Informational:		
3	Misc	Storm lid near road inlet needs replaced with a lid that reads "STORM". Also need to have lifting cables removed and grouted on top of parking lot inlet. 6/24/22 ES
		Storm lid has been replaced with the correct lid. 8/25/22 ES

Comments: