

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213689
Address: 1241 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, August 26, 2022

Corrective Action Required:

1	Misc	-Underslab plumbing not inspected and approved -Final grade, sod, downspout and sump pump extension -Ground meter to rod -Provide lighting outside front door -Provide handrail at foyer stair -Provide secondary lock for the slide door per security code -Remove all items from garage wall -Fb floor penetration below master bathroom tub -Complete electrical to water heater
---	------	---

Comments: