

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216461
Address: 3132 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mitchell Schwarz	Failed	Friday, August 26, 2022

Corrective Action Required:

1	Misc	-complete all fire blocking -complete all shear walls per plans -provide viewing for trusses above covered area -provide pressure at gas gauge -complete electrical -provide lateral bracing at A2 trusses -list subject to change complete items listed before reinspection
---	------	--

Comments: