

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216183  
Address: 2804 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, August 26, 2022

Corrective Action Required:

1	Misc	-protect NM with in 6' of attic access -address hole drilled closer than 2" to bottom of joist near basement door and bed room hall entry -fireblock vertically, horizontally every 10' in basement seal gaps -fire block into furr down bed 4 closet see beam and dead space to ceiling space -water shut off to to remain accessible -fireblock S most room
---	------	--

**Comments:**