

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210875
Address: 3057 NW THOREAU LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Friday, August 26, 2022

Corrective Action Required:

- | | | |
|---|------|---|
| 2 | Misc | <ul style="list-style-type: none">• final grading and sod• Obtain irrigation permit and provide back flow certification• Seal top of meter can and a/c disconnect• Attach AC whip 12" from disconnect• Pay all fees• Label non gfci outlets• Complete hardware and secondary lock on sliding door |
|---|------|---|

Comments: